

TEST REPORT

Client Name/Address	TENSE Elektrik Elektronik San. Tic. A.Ş. Muratpaşa Mah. Uluyol Cad. İşkent Sitesi E-F-G Blok No:29/E İç Kapı No:370 Bayrampaşa / İstanbul		
Name and Identity of Test Item	Multifunctional Timer Relay - ERX-10		
Order No.	2301.20	Sample Acceptance Date	28.01.2023
Num. Of Pages of The Report	21 + 22 pages of annexes 43 pages in total	Test Date(s)	27.01.2023-03.04.2023
Test Standard(s) Rating(s)	TS EN IEC 60947-1: 12.04.2021 / TS EN 60947-5-1: 19.03.2018 Clause: 8.2, 8.3.3.3, 8.3.3.4, 8.3.3.5.3, 8.3.3.5.4, 8.3.4 Un: 12-240V AC/DC, Ui: 240V, Uimp: 2.5kV, Ina: 5A, IP20 Detail(s) is/are given at the page 3.		
Test Result(s)	POSITIVE / Details, are given on the following pages which are part of this report.		

Remarks

TESTLA Elektrik Laboratuvarları accredited by TÜRKAK under registration number AB-0386-T for TS EN ISO/TS EN 17025:2017 as test laboratory.

Turkish Accreditation Agency (TÜRKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Tests marked in this test report (#) are not within the scope of accreditation obtained from TÜRKAK.

Seal	Date	Person in Charge of Test	Approval Date
	14.04.2023	 Mehmet ŞUMNU	14.04.2023  Caner EREN Laboratory Manager

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature is not valid.
Date format: dd.mm.yyyy